

The certificate of compliance validates the following:

Test report number:	RFTR16016	Inspection report number:	EEA-17-000642	Certificate number:	EEA-1702-0100
Date of issue:	22.01.2016	Date of issue:	28.03.2017	Date of issue:	23.09.2017
Date of expiry:	<i>Valid as long as the product, the test standard and the production process are not modified</i>	Date of expiry:	<i>Valid up to the Issuance of the surveillance inspection report (no later than the expiry date of the certificate)</i>	Date of expiry:	23.09.2018

Name of the manufacturer:	NEVPANEL YAPI MADEN ÜRETİM İTH. İHR. SAN. ve TİC. LTD. ŞTİ.	Name of the brand:	NevPanel, DragonBoardTürkiye, MagnumBoard
Factory address / region:	Eskişehir Organize Sanayi Bölgesi 28. Cadde No:8 ESKİŞEHİR/TÜRKİYE	Model / N°:	MgO Panel Thickness: 12 mm

Description of the product:	Partition Wall System
Test standard:	EN 1364-1:1999
Specification of test specimen:	Partition Wall System Consisting of Single Layer of MgO Panels

Test result:

FIRE RESISTANCE CLASSIFICATION
EI60, E 120

Name of test facilities	Efectis Era Avrasya Test ve Belgelendirme A.Ş.
Test facilities address/region:	TOSB TAYSAD Org. San. Bölğ. 15. Yol No :1 K :2 Şekerpinar-Çayırova KOCAELİ/TURKEY
Product application guide line (end use)	Intended to be used as partitioning

Signed by: Onur DAĞ
By delegation of the Technical Certification Director

The above certificate is valid only when the product is installed in accordance with the product application guideline (End use). To verify the validity of the product log onto our website www.efectis.com and type in the COMPLIANCE CERTIFICATE NUMBER

Onur DAĞ
Operation Manager

