

The certificate of compliance validates the following:

<b>Test report number:</b>	RFTR16017	<b>Inspection report number:</b>	EEA-17-000642	<b>Certificate number:</b>	<b>EEA-1702-00101</b>
<b>Date of issue:</b>	22.01.2016	<b>Date of issue:</b>	28.03.2017	<b>Date of issue:</b>	23.09.2017
<b>Date of expiry:</b>	<i>Valid as long as the product, the test standard and the production process are not modified</i>	<b>Date of expiry:</b>	<i>Valid up to the issuance of the surveillance inspection report (no later than the expiry date of the certificate)</i>	<b>Date of expiry:</b>	23.09.2018

<b>Name of the manufacturer:</b>	NEVPANEL YAPI MADEN ÜRETİM İTH. İHR. SAN. ve TİC. LTD. ŞTİ.	<b>Name of the brand:</b>	NevPanel, DragonBoardTürkiye, MagnumBoard
<b>Factory address / region:</b>	Eskişehir Organize Sanayi Bölgesi 28. Cadde No:8 ESKİŞEHİR/TÜRKİYE	<b>Model / N°:</b>	MgO Panel Thickness: 15 mm

**Description of the product:** Partition Wall System  
**Test standard:** EN 1364-1:1999  
**Specification of test specimen:** Partition Wall System Consisting of Single Layer of MgO Panels  
**Test result:**

FIRE RESISTANCE CLASSIFICATION
EI90, E 120

**Name of test facilities:** Efectis Era Avrasya Test ve Belgelendirme A.Ş.  
**Test facilities address/region:** TOSB TAYSAD Org. San. Bölğ.  
15. Yol No :1 K :2 Şekerpinar-Çayırova KOCAELİ/TURKEY  
**Product application guide line (end use):** Intended to be used as partitioning

**Signed by:** Onur DAĞ  
**By delegation of the Technical Certification Director**

*The above certificate is valid only when the product is installed in accordance with the product application guideline (End use). To verify the validity of the product log onto our website [www.efectis.com](http://www.efectis.com) and type in the COMPLIANCE CERTIFICATE NUMBER*

**Onur DAĞ**  
Operation Manager

